

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F6/DFS/MS/School/2019/NDZ/ 508

Dated: 12/3/19

FIRE SAFETY CERTIFICATE

Certified that the Vanasthali Public Sr. Sec. School Mayur Vihar Ph.III, Near Ruchica Petrol Pump, Delhi-96 owned/occupied by Vanasthali Public School, comprised of ground plus three upper floors was granted fire safety certificate vide letter no.F6/DFS/MS/School/2016/NDZ/298 dated 22/02/16. The School building was inspected by the officer concerned of this department on 08/03/19 in the presence of Mr. S.C.Jain (Manager) and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of condition under rule 38 and that the GF+FF+SF+TF of building is fit for occupancy Group B "Educational Building" with effect from 12/3/19 for a period of three years, subject to conditions printed overleaf.

Issued on 12/3/19 at New Delhi by



(Sunil Chawdhary)
Dy. Chief Fire Officer

To,

The Principal,
Vanasthali Public Sr.Sec. School,
Mayur Vihar Ph.III, Near Ruchica Petrol Pump,
Delhi-96.

Copy to:-

The Dy. Director of Education
D-Block, Anand Vihar, Delhi.

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry"